



6'-6 3/4" FIN. SOFFIT HT.

3'-0"

STOCK BASH UNIT

4 STUDS 6" O.C.

6'-6" WDW. HDGHT.

7'-3 1/2" PLATE HT.

6'-10 1/2"

3'-4"

2x4 STUDS 16" O.C.

4" BAT INSULATION

SEE PLANS FOR FINISH FL.

PLAY RM.

CORK TILE
1/4" PLY WOOD
1/2" INSUL-BD
3/4" SUB-FL.

NO BLOCKING

METAL FLASHING

1/2

PL. 2x4s

2x10 JOISTS 16" O.C.

SW 35

TILE

2x4 16" O.C.

LINTEL 2x2x6s

SOLID B

NO PASSE A

2x4 OUTLOOKER 16" O.C.

CONT. SOFFIT VENT.

WOOD SOFFIT

4" 1/2

1/2 1/2

6'-10 3/4" FIN. SOFFIT HT.

3'-0"

4 STUDS 16" O.C.

6'-10" WDW HDGHT.

9'-0" FIN. 1ST FL. TO FIN. 2ND FL.

redlines showing existing & code required conditions on original wall section

3/4" = 1'-0"

9'-15/8"

M. BED RM.

LIVING RM.

grade varies but this level @ master bedroom door

2x4 SOLE

2x10 CONT. HDZ.

FIN. GR.

3/4" FIN. FLOOR
3/4" SUB-FLOOR

HDZS. CUT BETWEEN

2x6 MUD SILL

2x4 SILL

2x10 JST 16" O.C.
NOTCH OVER MASONRY

code required: grade 4" below wood framing

wet & rotting wood

code required slope away from foundation

CONC BSMT FL.

3/4" WE